

GLENELG HIGH DRINKING WATER QUALITY REPORT
September 2009

Your school's water is supplied by one or more wells located on school property. The following report is provided by the HCPSS Office of Safety, Environment and Risk Management as a courtesy and is designed to resemble the required annual consumer confidence report provided to consumers by their public water utility/provider informing them about their drinking water. The language used in the report is based on EPA's Guidance document entitled "Preparing Your Drinking Water Consumer Confidence Report." Should you have questions or comments, please contact the Office of Safety, Environment and Risk Management at 410-313-6699.

PLEASE NOTE: All sampling results are below Federal and State Safe Drinking Water Standards.

MONITORING OF SCHOOL'S WATER SUPPLY

Below are the following contaminant categories that are regularly monitored to ensure safe drinking water quality.

Contaminant Category	Current Testing Frequency	Currently Tested By	Last Tested (available)
Bacteria	Monthly	Third Party Water Collector	June 2, 2009
Nitrate	Annually	Third Party Water Collector	January 8, 2009
Metals	Every 3 years	Third Party Water Collector	January 7, 2008
Arsenic	Every 3 years	Third Party Water Collector	January 11, 2008
Volatile Organic Compounds (VOCs) Eg. gasoline and disinfectant by-products	Annually	Maryland Department of the Environment	March 6, 2008
Synthetic Organic Compounds (SOCs) Eg. pesticides	Every 6 years	Maryland Department of the Environment	January 24, 2006
Lead and Copper (L&C)	Every 3 years	HCPSS Certified Water Sampler	June 10, 2008

DEFINITIONS

Parts Per Million (ppm) or Milligrams per Liter (mg/l) = a unit used to denote concentration of chemicals or other substances. The unit implies a part of something in one million parts of water or other substances. The following comparisons help in putting this concentration in perspective; 1 inch in 16 miles, 1 cent in \$10,000 or 1 drop in 60 quarts of liquid.

Parts Per Billion (ppb) or Micrograms per Liter (ug/l) = a unit used to denote concentration of chemicals or other substances. The unit implies a part of something in one billion parts of water or other substances. The following comparisons help in putting this concentration in perspective; 1 inch in 16,000 miles, 1 cent in \$10,000,000 or 1 drop in 60,000 quarts of liquid.

Action Level (AL)= the concentration of a contaminant which, if exceeded, triggers treatment or other requirements the water system must follow.

Maximum Contaminant Level (MCL) = the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG) = the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

GLENELG HIGH DRINKING WATER QUALITY REPORT
September 2009

EDUCATIONAL INFORMATION

Please note that a public notification is required when a standard is violated and is issued by the Office of Safety, Environment and Risk Management.

All sources of drinking water are subject to potential contamination by constituents that are naturally occurring or man-made. The presence of contaminants does not necessarily indicate that the water poses a health risk. Standards are set at very stringent levels for health effects and incorporate a margin of safety. Current standards are designed to protect children and adults. The standards take into account the potential effects of contaminants on segments of the population that are most at risk. **The MCL is based on drinking 2- liters every day at the MCL level for a lifetime (70 years) to have a one-in-a-million chance of having the described health effect.**

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers.

DETECTED CONTAMINANTS (per most recent test) – if a category and/or contaminant is not listed below it means it was not detected during the last test available.

Contaminant	Category	Level Detected	MCL	MCLG	AL	Potential Sources	Potential Health Effects (consuming in excess of MCL)
**MTBE	VOCs	0.9 ppb	N/A	20 ppb	N/A	Chemical additive to gasoline	
Copper	L&C	1.14 mg/l	N/A	1.3 mg/l	1.3 mg/l 90th percentile	Corrosion of household plumbing; erosion of natural deposits; leaching from wood preservatives	Copper is an essential nutrient, but some people who drink water in excess of AL over a relatively short amount of time could experience gastrointestinal distress. Chronic exposure could cause liver or kidney damage. People with Wilson's Disease should consult their personal doctor.

** Unregulated contaminant. The purpose of unregulated contaminant monitoring is to assist EPA in determining the occurrence of unregulated contaminants in drinking water and whether future regulation is warranted. MTBE is a fuel additive. Due to its widespread use, reports of MTBE detections in the nation's ground and surface water supplies are increasing. The Office of Water and other EPA offices are working with a panel of leading experts to focus on issues posed by the continued use of MTBE and other oxygenates in gasoline. EPA is currently studying the implications of setting a drinking water standard for MTBE. EPA issued a Drinking water Advisory that states concentrations of MTBE in the range of 20-40 ppb of water or below will probably not cause unpleasant taste or odor for most people.